



TENDER 19-08

HWY 19A PHASE III WATERMAIN & FORCEMAIN

ADDENDUM NO. 5

April 9th, 2019

This addendum forms part of the Tender Documents and shall be read, interpreted, and coordinated with all other parts. The costs of all elements contained herein shall be included in the submission. The following revisions, changes, corrections, additions, and or deletions supersede the information contained in the original Documents to the extent referenced and shall become part thereof.

Addendum Item 1 – Clarifications

1. In regards to Addendum No. 4 issued April 8th, 2019, Question 5 (c.) the response has been revised as follows:

The Contractor, working with the Owner, is responsible for emptying the 1300 LM of pipe. The Owner will operate all **of their existing** pumping systems and in line valves to assist the Contractor. **The Contractor is responsible for all temporary pumping.** There are also a number of access hatches to the existing 450mm pipe, which can be used to insert plugs and/or pumps as may be required. Per the specifications (33 34 01) the Contractor is to submit a "Forcemain Tie-In Plan".

2. Replace answer to question no. 3 in Addendum No.2 with the following: All BC Hydro costs related to any required pole relocations will be borne directly by the Owner. The Contractor is still responsible for any necessary coordination so as to include the related tasks within the Construction Schedule.

End of Addendum

Acknowledgement of this Addendum in your Tender submission is required.

Clinton J. Crook, SCMP, CPSM
Purchasing & Risk Management Officer